

Special Town Council Meeting August 2, 2017 at 6:00 p.m.

Present: Mayor Robert Stump, Councilmen: Mark McLaughlin, Mike Walter Public Works Director Curtis Green and Clerk Ginger Galiger.

Community members Michael Berry and Donna Stump. DEQ representatives; Jon Dilliard, John Price and Denver Fraser. Jim Murphy with DPHHS, Van Puckett Sanitarian and Bonnie Oneill Public Information Officer with Madison County

Annual Public Meeting

Mayor Robert Stump opened the meeting by thanking everyone for coming. Tonight's meeting is being held as a requirement from DEQ to update the public on last years lead exceedance level.

Mayor Stump reviewed the actions the Town has taken over the last year. The Town and DEQ supplied free bottled drinking water. Great West Engineering firm has designed an orthophosphate treatment system that will work in conjunction with an updated chlorination system. The system is currently being reviewed by DEQ. The Town also went into a six month cycle for our routine sampling sites which went from 10 to 20 sites. The results from the last two, six month sampling cycles have come back clear. There has also been extensive sampling of the wells.

The Town of Sheridan has received an all clear from DEQ on August 1, 2017 and we are allowed to return to an annual sampling regimen.

Jon Dilliard from DEQ commended the Town of Sheridan for "doing everything right".

The meeting adjourned at 6:35 p.m.

Approved: Robert Stump, Mayor

Attest: Ginger Galiger, Clerk